


GREENSTONE (USA), INC.

971 Corporate Way, Fremont, CA 94539, USA Toll Free: 877-206-5021, Fax: (510) 683-9313 jamal@greenstoneusa.com www.greenstoneusa.com

Vacuum Interrupter for Recloser

GTC-15/630-20A



Main Technical Data				
ltem	Unit	Value		
Rated Voltage	kV	15		
Lightning Impulse Withstand Voltage (Peak)	kV	100		
Short-time (1min) Power-frequency Withstand Voltage	kV	60		
Rated Frequency	Hz	50		
Rated Current	А	630		
Rated Short-time Withstand Current	kA	20		
Rated Duration of Short-circuit	S	4		
Rated Peak Withstand Current	kA	50		
Rated Short-circuit Making Current	kA	50		
Rated Short-circuit Breaking Current	kA	20		
Rated Operating Voltage	kV	15		
Mechanical Endurance	Operations	10000		
Clearance Between Open Contacts	mm	9±1		
Contact Closed Force Due to Bellows and Atmosphere	N	80±25		
Counterforce of Contact at Full Stroke	N	140±30		
Circuit Resistance at Min. Rated Contact Force	μΩ	≤25		
Contact Limit Erosion	mm	3		
Mass of Moving Parts	kg	0.6		
Internal Gas Pressure	Pa	<1.33×10 ⁻³		
Shelf Life	Years	20		
Rated Operating Sequence : O-t1	-CO-t2-CO-t3-0	:O-t2-CO-t3-CO-Lockout		
it is Min. Rated Starting Current(error ≤±10%) : rate Elec	raulic Pressure Control: twice as large as the d current of series coil. tron Control: adjustable.			

Mechanical Data of Switch Equipped With Interrupter			
ltem	Unit	Value	
Average Opening Speed	m/s	1.1±0.2	
Average Closing Speed	m/s	0.6±0.2	
Contact Bounce Duration at Closing Operation	ms	€3	
Out of Simultaneity of Contact Closing and Opening	ms	≤1	
Rated Contact Pressure	N	1800 +200	
Contact Pressure at Contact Touch Point	N	1300 +200	
Max. Rebound of Contact at Opening Operation	mm	2	
Overtravel During Opening	mm	€2	

 $Note: Meets \ or \ exceeds \ the \ electrical \ endurance \ requirements \ of \ class \ E2 \ for \ autoreclosing \ duty \ per \ IEC \ 62271-100 \ .$