

GREENSTONE (USA), INC. 971 Corporate Way, Fremont, CA 94539, USA Toll Free: 877-206-5021, Fax: (510) 683-9313 jamal@greenstoneusa.com www.greenstoneusa.com

## Vacuum Interrupter for Circuit-Breaker


Unit

k٧

Value

40.5

## GTD-40.5/1600-25A



Note 1: "☆" Within transformer oil or equivalent isolation medium; Note 2: "※" Rated characteristics to be given on request;

Note 3: Meets or exceeds the electrical endurance requirements of class E2 for autoreclosing duty per IEC 62271-100;

Note 4: The movable stem of the vacuum interrupter could noly suffe on more than 25N · m twisting force and in order not to damage the metal bellows, the movable stem should be prevent from rotation when assembling. For more requirements please check the Instructions of Usage.

Nated Voltage		+0.5
Lightning Impulse Withstand Voltage (Peak)	kV	185☆
Short-time (1min) Power-frequency Withstand Voltage	kV	70/95☆
Rated Frequency	Hz	60
Rated Current	А	1600
Rated Short-time Withstand Current	kA	25
Rated Duration of Short-circuit	S	4
Rated Peak Withstand Current	kA	63
Rated Short-circuit Making Current	kA	63
Rated Short-circuit Breaking Current	kA	25
Max. Dc Component		40%
Switch Operations of Rated Short-circuit Breaking Current	Operations	20
Rated Single Capacitor Bank Breaking Current	А	400※
Rated Back-to-Back Capacitor Bank Breaking Current	А	400※
Mechanical Endurance	Operations	10000
Clearance Between Open Contacts	mm	18±1
Contact Closed Force Due to Bellows and Atmosphere	N	110±40
Counterforce of Contact at Full Stroke	N	210±40
Circuit Resistance at Min. Rated Contact Force	μΩ	≤20
Contact Limit Erosion	mm	3
Mass of Moving Parts	kg	1.6
Internal Gas Pressure	Ра	<1.33×10-3
Shelf Life	Years	20
Rated Operating Sequence	Open-0.3s-CO-180s-CO	

Main Technical Data

ltem

Rated Voltage

## Mechanical Data of Switch Equipped With Interrupter

ltem	Unit	Value
Average Opening Speed (first 12mm)	m/s	1.7±0.3
Average Closing Speed (last 6mm)	m/s	1.3±0.3
Contact Bounce Duration at Closing Operation	ms	≤3
Out of Simultaneity of Contact Closing and Opening	ms	≤2
Rated Contact Pressure	N	2900 +300
Contact Pressure at Contact Touch Point	N	2050 +210
Max. Rebound of Contact at Opening Operation	mm	3
Overtravel During Opening	mm	≤3